

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225393
Address: 801 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------|------------------|----------|--------------------------|
| Above Ceiling Inspection | Mitchell Schwarz | Failed | Monday, October 16, 2023 |

| | |
|-----------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Corrective Action Required: | |
| 1 Misc | Second floor bath only. Install bath vents |
| Corrective Action Required: | |
| 2 Misc | First floor Inspected. -dayroom border of drop ceiling -bathrooms -conference room border of drop ceiling -captain office border of drop ceiling -covered patio on W side -east patio/entrance -secure MC within 12" of boxes 10/11/23 Mitchell Schwarz |

Comments: