## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRSUBD20230406Address:1204 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer Construction Inspection	Devon Perry	Partial	Monday, October 16, 2023
Informational:			
1 Misc	stub. Then today they star foot of pipe. 7-12-23 NS Site visited and pipe. From A-1 and the cro installing the private tie in before the rain hits. I stay 7-13-23 NS Site visited the is working on sewer to co rock. Crew 2 put in D-2 an started to hit major rock. I 7-14-23 NS Site visited cre then left before lunch. 7-17-23 NS Site visited and rock. no pipe put in 7-19-23 NS Site visited and rock. No pipe installed 7-20-23 NS Site visited and rock. 1 stick installed	e crews are working at A-2 n nnect to D-2 Man hole. Crev d back filled Crew 1 only ma	A-1 and laid about 100 aid about 50 feet of A-2. Also the crew is b bury them tonight nanhole. The other crew w is running into a lot of ade it 100 feet until they about 50 feet of pipe ver. sewer but are hitting sewer but are hitting

7-24-23 NS Site visited and the crews are working on sewer but are hitting rock. 2 sticks and MH installed

7-25-23 NS Site visited and the crews are working on sewer but are hitting rock.

7-26-23 NS Site visited and the crews are working on sewer they put in 300 feet of pipe today with out hitting rock.

7-27-23 NS Site visited and the crews are working on sewer they put in 150 feet of pipe today with out hitting rock. Man Hole A-2 A-3 A-4 are put in the ground. with a 1% slope

7-31-23 NS Site visited workers are not working today since rain.

8-1-23 NS Site visited Crews are working on the sewer main that runs up to the cu-de-sac's.

8-2-23 NS Site Visited and crews are rained out

8-3-23 NS Site Visited and crews are rained out

8-4-23 NS Site Visited and crews are working on Cu-de-sac installed MH-6-1 and MH C-1

8-7-23 NS Site visited and the crews are from MH C-1 to MH C-2

8-8-23 NS Site visited and the crews worked on sewer stubs and are back filling MH C-1 to C-2

8-9-23 NS Site visited crews are not working because of rain

8-10-23 NS Site visited and crews are working on sewer stubs in the middle cu-de-sac. worked through lunch

8-14 NS Site visited crews worked on MH B-2

8-15 NS Site visited and crews finished sewer line and started pouring inverts into man hole.

8-17-23 NS Site visited and crews started to work on Sewer line B

8-18-23 NS Site visited and the crews are working on finding utilities for the water bore to be put in place crossing Lakewood way

9-27-23 DP. Crew is conducting their own sewer testing in preparation for official testing that will be conducted next week.

10-12-23 NS Site visited and crew is doing sewer testing

10-13-23 NS Site visited and crew is doing sewer testing

10-16-23 NS Crew is done today doing sewer testing all of the man holes and pipes passed the vacuumed test and mandrill test. Water came out and check the man holes and only two did not pass because of trash and the one man hole does not have the correct cover.

## **Comments:**