



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110420, Building Permit - Commercial
Address: 910 NW BLUE PKWY, Unit:P, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Tuesday, July 19, 2011

Corrective Action Required

1	MISC	RESOLVE FIRE DEPARTMENT ISSUES
Corrective Action Required		
2	MISC	PERMANENT LABEL GAS SERVICE PER DISCUSSION
Corrective Action Required		
3	MISC	PERMANENT LABEL ELECTRICAL SERVICE PER DISCUSSION
Corrective Action Required		
4	MISC	DESIGNATE ELECTRICAL SERVICE PANELS PER PRINT
Corrective Action Required		
5	MISC	COMPLETE LABELING ELECTRICAL PANEL CIRUIT POSITIONS -- BOTH PANELS

Comments: