

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20222876  
Address: 2121 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Failed	Tuesday, October 17, 2023

Corrective Action Required:

- |   |                          |   |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | <ul style="list-style-type: none"><li>- Lock out needs to be installed on the oven breaker</li><li>- Ledger locks on the back deck needs to have nuts on the opposite side of the driver head</li><li>- Irrigation permit is required for sprinkler system already installed</li><li>- Sod is not installed</li></ul> |
|---|--------------------------|---|

Comments: