

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20231955  
Address: 2125 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Dustin Agcopra	Partial	Tuesday, October 17, 2023

Informational:  
1 Misc 10-17-23 Dustin A, DW is formed. Aggregate is compacted. Depth is in compliance. Must maintain under 2% through approach . Approves to pour.

**Comments:**