

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232450
Address: 3216 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, October 18, 2023

Corrective Action Required:

1 Misc

- anchor bolts to be in the middle third of sill plate
- secure and complete gas line installation at fire place
- sold block sheathing breaks above windows at fireplace
- sold block sheathing breaks in bed 2 N wall
- missing stud bed 4 closet
- bring supply in basement bath down through furr down
- unblock and pan return air for bed 3
- provide full support onto steel column for beam at stairwell in basement

Comments: