

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20223840  
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Robb Popp	Failed	Thursday, October 19, 2023

Corrective Action Required:

1	Misc	**Hard lids at entry and lobby approved to cover -Remove all border tiles for inspection -Complete all electrical -Secure all mc within 12" of boxes -Remove rock at hard lids in bathrooms or provide access for inspection -Inspection incomplete
---	------	--

**Comments:**