

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20235158  
Address: 2047 SW HOOK FARM DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                               | Inspector:       | Outcome: | Date:                    |
|---|------------------|----------|--------------------------|
| <b>All Rough Inspection - Residential</b> | Mitchell Schwarz | Failed   | Friday, October 20, 2023 |

Corrective Action Required:

1 Misc

- provide city stamped plans on site
- complete hvac
- secure gas line in ceiling space with metal hangers
- fire block throughout basement
- provide pressure at gas gauge for inspection
- provide 1 1/4" clearance for gas line in stud bay or approved protection plate

S wall

**Comments:**