

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220707
Address: 3124 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, October 20, 2023

Corrective Action Required:

1	Misc	-provide issued lawn irrigation permit -garage door to be self closing and latching -set screw sheered off at water anti syphon device -all outlets in kitchen to be arc fault protected -provide gutter vent for future basement bath -secure A/c whip within 12" of disconnect -
---	------	--

Comments: