

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212708
Address: 4705 NE FREEHOLD DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Friday, October 20, 2023

Partial Correction:

1 Misc

****TCO CANNOT BE ISSUED UNTIL OTHER EXPIRED TCO PERMITS ARE CLOSED**

- Provide sewer tracer wire port at grade
- Provide min 6" clearance from bottom of siding to grade
- Secure bottom bracket of railing at basement stairs

Comments: