

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234101
Address: 811 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mitchell Schwarz	Failed	Friday, October 20, 2023

Corrective Action Required:

1 Misc

- provide solid blocking for Ada grab bars in restroom
- boca plate protection at top of restroom wall for dwv
- provide compliant electrical in all patient care areas per code section 517.12 of 2017 NEC

Comments: