

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231955
Address: 2125 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Passed	Monday, October 23, 2023

Informational:
1 Misc 10-17-23 Dustin A, DW is formed. Aggregate is compacted. Depth is in compliance. Must maintain under 2% through approach . Approves to pour.
10-23-23 DW is poured . Slopes are in compliance . Passed

Comments: