

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20230406
Address: 1204 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Aggregate Base	Nick Scott	Passed	Monday, October 23, 2023

Informational:
1 Misc 10-23-23 Site visited and crews showed up to put base down and they completed it today. There are two man holes that will have to be re dug up and Raised or Lowered to meet ADA standards. B-1 and C-1 tomorrow they will start on surface.

Comments: