

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED

---

Permit #: PRCOM20231204  
Address: 2951 SE SHENANDOAH PKWY, LEES SUMMIT, MO 64063

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Bobby Richest	Failed - Stop Work	Tuesday, October 24, 2023

Informational  
1 Misc

8-7-23 BR Erosion control needs to be fix. Silt fences need to be added around the construction area as well as debris and brush need to be removed around existing silt fence, so silt fence is visible. Need to add more rock in entrances to help control less dirt getting on the roadway.

8-22-23 BR Erosion control is up and working order.

10-5-23 BR Erosion control fence need to be repaired. There are several locations on the fence that needs to repair to brakes in the fence line.

10-19-23 BR Erosion control fence need to be repaired. There are several locations on the fence that needs to repair to brakes in the fence line

10-23-23 BR Erosion control fence need to be repaired. I spoke with contractor this morning about getting fence repaired. Which the contractor informed me that they was getting the

**CITY OF LEE'S SUMMIT**  
**Development Services Department**  
**220 SE Green Street**  
**Lee's Summit, MO 64063**  
**(816) 969-1200    FAX (816) 969-1201**

fence repaired at noon today. It's 4:00 pm and the fence is still not repaired which needs to be done to a rain storm coming tonight.

10-24-23 BR Erosion control is not to LS Specifications site is shut down.

**Comments:**