

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20223840
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	John Jackson	Failed	Tuesday, October 24, 2023

Corrective Action Required:

1	Misc	10/19/23 EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. -Clean silt and debris from street, sidewalks and inlets and provide erosion control methods at perimeter immediately. Erosion control is to be in place until permanent vegetation is established 10-24-23 Dustin A, No erosion control is on site, Silt is on sidewalk. Met with GC informed him again that erosion control had to be in place and silt on sidewalks had to be in by tomorrow morning or stop work order will be issued.
---	------	---

Comments: