

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20224767  
Address: 1100 NW MAIN ST, Unit:D, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Miscellaneous Inspection</b>	Khanh Nguyen	Failed	Tuesday, October 24, 2023

Corrective Action Required:

1	Misc	-Submit the racking & conveyor plan to the city for approval under separate permit PRCOM20233787
		-Rack near conveyor-tighten all column base anchors

**Comments:**