

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20232451  
Address: 2611 SW BARLEY FIELD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Tuesday, October 24, 2023

Corrective Action Required:

1	Misc	-anchor bolts in garage to be in the middle 1/3 of sill plate. -address plumbing and electrical drilled closer than 2" above garage entry bathroom (fix not to engineer specifications) -address holes drilled closer than 2" to one another above master bed entry (fix not to engineer specifications)
---	------	--

Comments: