

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20233804  
Address: 1038 SW FIORD DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Wednesday, October 25, 2023

Corrective Action Required:

1	Misc	- Shim gap on trusses on breakfast area against steel beam - Strap top plate second floor above door and bedroom 2 , short overlap - Missing 2 LTHJA26 brackets second floor trusses North West side
---	------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**