

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221049

Address: 808 NE ALGONQUIN ST, LEES SUMMIT, MO 64064
806 NE ALGONQUIN ST, LEES SUMMIT, MO 64064
64064804 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|--------------|----------|-----------------------------|
| Rated Assembly Inspection | Khanh Nguyen | Failed | Wednesday, October 25, 2023 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Close excessive gap at ridge above garages -Close off roof ventilation opening within 4 ft of firewall above unit 808 bathroom |
|---|------|--|

Comments: