

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220388
Address: 2034 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, October 25, 2023

Corrective Action Required:

1	Misc	-anchor bolts to be in the middle 1/3 of sill plate -return air stud cavity shall not convey air from more than one floor(see dining room) -seal return air space at master bed entry and in master bedroom -fireblock wall space to ceiling space at master bed E wall -nail exterior wall studs together to code and plans -h2.5 missing on header at bed 4
---	------	--

Comments: