



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110319, Building Permit - Commercial
Address: 500 SW LONGVIEW RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------|---------------|----------|-------------------------|
| Above Ceiling Inspection | Mike Copeland | Failed | Thursday, July 21, 2011 |

Corrective Action Required
1 MISC

ROOM 203: FLEX DUCT CONNECTORS ARE TO BE TAPED AND CONNECTED PER FLEX DUCT MANUFACTURERS INSTRUCTIONS AT CONNECTIONS TO MAIN TRUNK.

Comments: