

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234293
Address: 1220 NW MAIN ST, Unit:A, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	Robb Popp	Failed	Thursday, October 26, 2023

Corrective Action Required:

1	Misc	-Provide permanent address tag for unit A meter -Paint all exterior metallic gas lines with corrosion resistant paint
---	------	--

Comments: