



Framing & Structural Steel Report

Report #: 0028-000001-00

KCK Office

1100 W Cambridge Circle Dr., Suite 700
Kansas City, KS 66103
Phone: 913-627-9040

Client:

Forge Construction
1307 Union Avenue
Kansas City, MO 64101

Project:

23-5628
Forge - RTU Reinforcement Inspection
-
Lee's Summit, MO

Activity Date: 10/17/2023

Technician: Standridge, Paul

Weather: Work Performed Indoors

Temperature (F): 51

OBSERVATIONS

DISCREPANCY: No

Type of Observation: Structural Steel / Welding

Location: Structure - Interior Framing

Location Details: New RTU framing, joist web reinforcement, and joist reinforcement and welded connections.

Plans / Details Referenced: Sheet #'s: S2.2, S4.0, S4.1, S4.2

Engineer of Record: Michael Brunin

Observations:

Observed welded connections for the new RTU structural steel framing, joist reinforcement and joist web reinforcement.

The observations detailed above were found to be in substantial compliance with the project documents.

Reviewed By:

Caw, Angie