

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234293
Address: 1220 NW MAIN ST, Unit:A, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Friday, October 27, 2023

Corrective Action Required:

1	Misc	Demining wall: Screw pattern ok *Ok to tape -Seal penetrations at bar joists on north side and seal conduit at south side
---	------	--

Comments: