

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20230832
Address: 612 SW WALDEN LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Shawn Hoffman	Failed	Friday, October 27, 2023

Corrective Action Required:

1	Misc	- Install GFCI outlet in bathroom - Install smoke detector - All finished areas to be AFCI protected - Combustion air from outdoor is approved (G2407.6.2 one permanent-opening)
---	------	--

Comments: