

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20215559

Address: 451 SE OLDHAM PKWY, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection	Patrick Schonfeldt	Partial	Monday, October 30, 2023

Informational:

1	Misc	10-30-23 PS Contractor installed sanitary service line from building on east side turning corner at front north side for partial. Oil/sand interceptor installed and meets plan requirements, 4" cleanouts installed on both sides of interceptor. Contractor omitted grinder pump as he was able to achieve required fall.
---	------	---

Comments: