

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20226269
Address: 2206 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Alex Fischer	Failed	Monday, October 30, 2023

Partial Correction:

1	Misc	-Nail all exterior corners per code, insufficient nails -Missing fire blocking at top of chase near kitchen -Install security blocking at exterior doors per Chapter 7 of the City code -Missing fire blocking under garage stairs -Install fire blocking in ceilings of electrical room -Address insufficient 2x4's at exterior corners in basement
---	------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: