

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222785

Address: 1220 NW MAIN ST, Unit:IR, LEES SUMMIT, MO 640861220 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Monday, October 30, 2023

Corrective Action Required:

1	Misc	-Complete corrections for all other departments -Provide permanent tags at all separate gas services -Label RTUs -Paint rooftop gas lines with corrosion resistant paint -Provide site address -Provide unit address at all doors -Firetape partial hole at riser room
---	------	--

Comments: