

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234293
Address: 1220 NW MAIN ST, Unit:A, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Monday, October 30, 2023

Corrective Action Required:

1	Misc	-Complete all corrections for LSFD -Shell must have TCO before occupancy -Complete break room sink and countertop -Label RTUs -Paint exterior metallic gas lines on roof -Provide permanent tag at separate gas services -Provide unit address at all doors ***OK TO STOCK AND TRAIN ONLY, DO NOT OCCUPY
---	------	---

Comments: