CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223951

Address: 2773 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Shawn Hoffman Failed Tuesday, October 31,

Residential 2023

Corrective Action Required:

1 Misc - no water inspection on file yet has been installed

- Provide 2" x 2" washers at portal frame

- Strap top plate at entry and bedroom 2 not tied

- Secure CSST within 12" from fire place

- Fire block top of fire place

- Broken truss C8 and C9 at dryer vent, provided engineers letter and

complete repair

- Nail off exterior corners in master bedroom

- Solid block cantilevers in basement

- Provide security blocking basement door

- Tighten anchor bolts in basement

- Fire block top plate at Egress window bedroom 4

Comments: