

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20225640  
Address: 401 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Robb Popp	Partial	Tuesday, October 31, 2023

Corrective Action Required:

1	Misc	-Protect all pex and dwv within 1.25" to face of framing -Install grommets at pex lines bored through steel framing -Install bonding screw and jumper at metallic box in storage area -Land MC at exterior box near shower
---	------	---

\*OK TO INSULATE AND 1 SIDE. DO NOT COVER INSPECTION ITEMS

**Comments:**