

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20230406
Address: 1204 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 1	Nick Scott	Partial	Tuesday, October 31, 2023

Informational:
1 Misc 10-31-23 NS Site visited and talked to the Forman and the pipe was chlorinated on 10-26-23 and they are going to put more in because the last part of the line does not have enough chlorine in it.

Comments: