

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232039

Address: 1001 NW CHIPMAN RD, Unit:123, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Passed	Tuesday, October 31, 2023

Corrective Action Required:

1 Misc -Provide protection plates at all dwv within 1.25" to face of framing

Comments: