

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20213806  
Address: 3809 SW MARYVILLE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Alex Fischer	Not Ready	Monday, October 30, 2023

Corrective Action Required:

1	Misc	-Missing railing and spindles at garage stairs -Remove plastic cover forms smokes in basement
---	------	--

Corrective Action Required:

2	Misc	Sec. 7-1409.1. - Front and street side exterior lighting. All front and street side door entrances shall be protected with a minimum of one light outlet having a minimum of sixty (60) watts of lighting (or energy efficient equivalent). Those fixtures placed below eight (8) feet shall be fixtures manufactured such that the light source is not "readily accessible" as defined in the adopted National Electrical Code (NEC).
---	------	---

(Ord. No. 8584, § 1, 3-19-2019)

**Comments:**