

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20215559

Address: 451 SE OLDHAM PKWY, Unit:A, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Proof Roll</b>	Patrick Schonfeldt	Partial	Thursday, November 02, 2023

Informational:

1	Misc	10-20-23 PS Contractor performed proof roll on aggregate base for concrete located at rear south side of building "A" between existing building. Areas inspected approved to pour concrete
		11-2-23 PS Inspected proof roll on NE side of parking lot where new asphalt will be placed at parking stalls. Approved for surface.

**Comments:**