

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223951
Address: 2773 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Alex Fischer	Failed	Friday, November 03, 2023

Partial Correction:

1	Misc	- Solid block cantilevers in basement -Missing 2x4 next to steel post at basement stairs -Loose 2x4 next to steel post at basement stairs
---	------	---

Comments: