

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20220570

Address: 1100 NW MAIN ST, Unit:FP, LEES SUMMIT, MO 64086
1100 NW MAIN ST, Unit:IR, LEES SUMMIT, MO 64086
1100 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	Steve Robbins	Passed	Friday, November 03, 2023

Informational:

1	Misc	09/06/23 Wednesday JMJ Erosion control appears to be functioning properly.
---	------	---

		09/12/23 Wednesday JMJ Erosion control appears to be functioning properly.
--	--	---

Corrective Action Required:

2	Misc	09/25/23 Monday JMJ (KADEAN)
---	------	--------------------------------

Erosion control failure.
The grounds around building one have been grade but no vegetation has been established. After the weekend rains there are area the Southside from East to West that have silt in drive and parking lot area.

Informational:

3	Misc	The silt fence has been installed and the silt was cleaned upl.
---	------	---

Comments: