

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234049

Address: 2208 SW OSAGE DR, LEES SUMMIT, MO 640822210 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Kyle Beard	Failed	Monday, November 06, 2023

Corrective Action Required:

1	Miscellaneous Correction	Erosion control is required and needs to be maintained until occupancy
---	--------------------------	--

Corrective Action Required:

2	Miscellaneous Correction	Full erosion control is not in place. CLEAN the street of all mud and gravel. No inspections will proceed until erosion control and removal of debris from street are completed 11/06/23 KBEARD
---	--------------------------	--

Comments: