

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232038
Address: 910 NW BLUE PKWY, Unit:R, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Tuesday, November 07, 2023

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-Health department approval required-Approval from LSFD required-Provide cover plate at open box by hand sink-Provide cover plate at box by 3 compartment sink-Cut drain pipes at 3 compartment sink and mop sink to be 2x pipe diameter, min 1" above flood level rim-Secure drain pipe at mop sink-Provide plumbing protection under sink in restroom-Restroom mirror to be max 40" off to reflective surface-Provide non absorbant finish at restroom min 48" off or documentation of product used. (Must be epoxy based paint)
---	------	--

Comments: