

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20192646  
Address: 3201 NW PARAGON PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Robb Popp	Partial	Wednesday, November 08, 2023

Corrective Action Required:

1	MISC	-Provide bocca plates, secure dwv at riser room -Seal through floor penetrations at restroom walls
---	------	---

Informational:

2	Misc	In-wall OK to cover: -Ceiling soffit wall west of the restroom -Soffit at East building -Stairwell walls -Restrooms 206/207 except at drinking fountain alcove and north wall -Column at breezeway
---	------	---

Comments: