

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20223975
Address: 204 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Kyle Beard	Partial	Wednesday, November 08, 2023

Informational:		
1	Miscellaneous Correction	The Ufer is located on the west side of the footing near the Southwest corner. This is a partial footing pass only. The footing for the building itself passed and other footings will be call in for inspection at a later date 11/08/23 KBEARD

Comments: