

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231016
Address: 2075 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Robb Popp	Failed	Wednesday, November 08, 2023

Corrective Action Required:

2	DCM3 ESC	**11/8/23
	REQUIRED 2 DAY	EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. -PROVIDE EROSION CONTROL AT PERIMETER OF LOT **IF NOT IN COMPLIANCE IN 2 BUSINESS DAYS, A STOP WORK ORDER WILL BE ISSUED

Comments: