



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20100137, Building Permit - Commercial  
Address: 1255 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Hood/Duct Inspection</b>	John Borns	Partial	Tuesday, July 26, 2011

Partial Correction  
1 MISC

LIGHT TESTING OF GREASE DUCT: SHOP WELDS TESTED OK 7/21/11; FIELD WELDS TESTED OK 7/26/11

Corrective Action Required  
2 MISC

DUCT WRAP SUBJECT TO APPROVAL WHEN IN PLACE

Corrective Action Required  
3 MISC

NEBBS-CERTIFIED COMMERCIAL KITCHEN HOOD PERFORMANCE TEST REPORT REQUIRED TO BE SUBMITTED TO INSPECTOR WHEN EQUIPMENT IS OPERATIONAL AND BEFORE COMMERCIAL USE; SMOKE CAPTURE TEST TO BE WITNESSED BY INSPECTOR BEFORE ANY OCCUPANCY IS APPROVED.

**Comments:**