

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215800  
Address: 1600 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                | Inspector:     | Outcome: | Date:                       |
|----------------------------|----------------|----------|-----------------------------|
| <b>Driveway Inspection</b> | Dustin Agcopra | Partial  | Thursday, November 09, 2023 |

Informational:

|   |      |   |
|---|------|---|
| 1 | Misc | 11-8-23 Dustin A, DW is not ready will come back tomorrow (11-9) Curb will need to be poured before approach is poured<br>11-9-23 Dustin A, DW is framed and aggregate is compacted. Will need to maintain ADA compliant slopes through approach. Approved to pour. |
|---|------|---|

**Comments:**