

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233098
Address: 1804 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|-----------------------------|
| Occupancy Inspection - Codes Residential | Kyle Beard | Failed | Thursday, November 09, 2023 |

Corrective Action Required:

| | | |
|---|--------------------------|--|
| 1 | Miscellaneous Correction | 1804 occupancy driveway lamps need to be sealed at the top Exterior sump pump extension does not exceed 3 feet out from the foundation Seal top of a/c disconnect Seal top of electrical meter box Pay fees associated with this permit |
|---|--------------------------|--|

Comments: