

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20226005  
Address: 1901 SW RIVER RUN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Curb - Proof Roll</b>	Patrick Schonfeldt	Passed	Thursday, November 09, 2023

Informational:	
1      Misc	11-9-23 PS Observed proof roll for both parking lot surface and curbs. Rutting observed at mid point of parking lot. Contractor to add additional base aggregate and compact before pouring surface.

**Comments:**