

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226005
Address: 1901 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	Patrick Schonfeldt	Passed	Thursday, November 09, 2023

Informational:	
1 Misc	11-9-23 PS Observed proof roll for both parking lot surface and curbs. Rutting observed at mid point of parking lot. Contractor to add additional base aggregate and compact before pouring surface.

Comments: