

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232910
Address: 2764 SW 11TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, November 09, 2023

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Address over notched studs (2) at single garage- Provide hanger for 4 LVL pack at garage entry- Plan calls for 3 studs under each side of double Lvl at kitchen wall- 3 studs required at exterior corner at master closet and tub- Fire block seam at sheet break top plate ductwork chase master bathroom
---	------	---

Comments: