

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20223170  
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Failed	Thursday, November 09, 2023

Corrective Action Required:

1	Misc	-Complete corrections for all other departments -Pay all fees -Tighten exterior GFCIs at front left and back of building -Paint exterior gas lines on roof -Label RTUs -Install screens at rooftop storm drains
---	------	--

**Comments:**