

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20223840
Address: 1410 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Thursday, November 09, 2023

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-Pay all fees-No occupancy can be issued until Shell permit is finalized-Complete corrections for LSFD-Obtain Health Department approval-Correct floor elevation changes greater than 1/2" at entry doors (install mats)-Provide backflow devices at all carbonated beverage machines, coffee makers, ice machines and non carbonated dispensers (ASSE 1022 at carbonated machine, ASSE 1022 or 1024 at others)-Air gap at drain pipes to be 2x effective opening of pipe diameter-Install restroom mirrors to be 40" aff max to reflective surface-Install restroom accessories to be ADA compliant-Sink in Men's room to be no greater than 34" aff-Toilet in Women's room to be 16"-18" to center from side wall-Receptacle in men's room loose-Paint exterior gas lines at rooftop-Label RTUs-Install dead fronts at electrical panels <p>**OK TO STOCK AND INSTALL REST OF EQUIPMENT AND ACCESSORIES. DO NOT OCCUPY</p>
---	------	---

Comments: